



HALL 10.2

Hall floor	compound screed sealed
Suspensions from the hall ceiling	Yes – HTA 28/15 p = 0.5 kN/m, e (at least) = 0.25 m
Building height Niches north/south	3.50 m 3.00 m
Illumination	400 Lux
Daylight	None
Stand construction	Stands should be as open and transparent as possible on all aisle sides (at least 70%). The basic construction height is 2.50 m. Above this height, it is necessary to ensure that the rear sides of walls facing neighbouring stands are smooth and generally of a neutral colour (e. g. white or light grey).